



DISTRICT
ENERGY
IN CITIES



Increasing Investments in District Energy Systems in Cities – a SE4All Energy Efficiency Accelerator – City of Belgrade

Final results of the interconnection study



Founded in 2007

*Spinoff of the
Operations Research
(OR) team of the
University of Bologna*

*We develop **solutions**
and services based on
analytics &
optimization*



*Young and highly skilled
team: everyone holds a
STEM Master Degree*

*or **PhD***

*We are
Data scientists,
Business consultants,
Operations Research
specialists,
SW application dev.
professionals*



*We work for **medium**
and large enterprises
in **several industries:***

*Energy, Waste,
Logistics, Retail, etc.*

*We participate in the
scientific community
and active in fostering
“**OR in Practice**”*



DISTRICT ENERGY
IN CITIES
INITIATIVE



2 main Offices

*Consultancy services
and Commercial HQ in
Bologna*


*SW Factory in **Cesena***



Proposition in DH



DISTRICT ENERGY
IN CITIES
INITIATIVE




Network Optimisation



DISTRICT ENERGY
IN CITIES
INITIATIVE



THE BUSINESS OBJECTIVE




How to plan District Heating (& Cooling) **Network Development** roadmaps that maximise the Return on Invested Capital (i.e. **Net Present Value**), amongst countless possible options?

CHALLENGES FOR DECISION MAKING



Geographic dimension of the business issue (overcome Excel)



Several possible potential **scenarios** (what-if)



Economic value assignments on **costs and revenues sides**




Thermal-hydraulic feasibility analysis of proposed solutions




DHN: the solution




DISTRICT ENERGY
IN CITIES
INITIATIVE



Existing &
potential pipings




Existing &
potential users



Existing &
potential plants




Import + Puntual
editing /drawing



Advanced
Scenario Mgmt



Tariffs &
Capex/Opex



Technical
constraints




Financial
parameters




Application Case



DISTRICT ENERGY
IN CITIES
INITIATIVE



Via Martinetti - Milan



DATA	AGGIORNAMENTO	REALIZZATO	VERIFICATO
a2a energia thermique			
PROGETTO n. 150/149			
DATA	GENNAIO 15	SCALA Vara	DATA
COMUNE DI MILANO		Posta tassegas nelle via Martinetti, Branca, Molazzetto e Zappa	
INIZIO 2016	DURATA app. 150	TUBAZIONI INF. A 0,04 BAR	TDS. 962 mng da postura m
REPARTO STRADE	2	PRESSIONE INF. A 1,50 BAR	BT
VIGILANZA URBANA	7	PREZZO CNE INF. A BAK	9KV
CONSIGLIO DI ZONA	7	DA COLLOCARE	23KV
ATTRAVERSAMENTI MANOVRE/SEZIONE		DA ABANDONARE	
ESISTENTI	MARCATI/PED.	DA RIMUovere	TELEFONICO
DA COSSIGLIE	CARICATO/STATA	DA INTLARE	DA SOTTRARRE
SEGNALETICA CROZZONALE		CAVI PROTETT. CATOD.	CABINA PROVVISORIA
SCAVO TOT. m	750	CAVI TELECONTROLLO	CAVI LP./SERM./TELECONTROLLO
ASSAGGI	10	ARRIVI	TDS. 952 mng da postura m
MODIFICATO	DATA MODIFICA	VALVOLA	BT
DISGNATO	Studio Avail	DCAVI	CAVODOTTO SF
VISIO	Genna	TUBAZIONI TERARSICALDAMENTO	FIBRE OTTICHE
		PRESSIONE INF. A 1,50 bar	TELETONICO
		DA COLLOCARE	= 1500 COASSIALE
		REVISIONE	PAU ARRIVATO P
			ARRIVATO P

DECISION DRIVERS INTEGRATION

The tool allows for a smooth transition of the feasibility and commercial analysis from Marketing & Sales to Engineering department



The Challenge in Beograd



DISTRICT ENERGY
IN CITIES
INITIATIVE



The key challenge: identify the optimal new network configuration

Analyze the technical and economic impacts of:


- Different interconnection scenarios
- Different piping sizing
- Integration of “carbon-friendly” energy sources

Goal: striking a balance between complex conflicting options

Technical and operational drivers




One vs multi-connections



Resource allocation




Renovation vs New Piping



Reference load to dimension



Peak vs Low Load




OPTIT
optimal solutions



Project approach




DISTRICT ENERGY
IN CITIES
INITIATIVE



Subject of the analyses



DISTRICT ENERGY
IN CITIES
INITIATIVE



NEW CONFIGURATIONS

- **Perspective users** to be connected (**88 MW_{th}**)
- New (greener) sources: **Thermal Plant (600 MW_{th}) + WTE (56 MW_{th})**
- **Planned construction** of new piping and **refurbishing of existing** piping

TWO SEPARATE HYDRAULIC SYSTEMS

- **Temperature-based regulation** (always nominal flows) in **Zemun-NB**
- **Flow-based regulation** (demand-dependent flows) in **Konjarnik-NB-Dunav**



New Zemun-NB system



DISTRICT ENERGY
IN CITIES
INITIATIVE



WORK CONDITIONS

- The connection must allow Zemun's current plant shut-down
- NB backbones have tight constraints (supply and Δp at the plant)
- The new network configuration must follow the current hydraulic regime and temperature-based regulation
- Can leverage upon presence of closed pipes linking NB main backbones

INVESTIGATION LINES

- Hydraulic balance of new network configurations
- Impact of opening different sets of closed pipes
- Impact of the new backbone construction
- Characterization of the pumping stations


Connection of a new user ($10 \text{ MW}_{\text{th}}$)

New planned DN350 backbone in Zemun

New pumping stations

New source connection (TENT A)

Connection Zemun - NB



New Zemun-NB system



DISTRICT ENERGY
IN CITIES
INITIATIVE



NEW NETWORK CONFIGURATION

Δp distribution

- 1.0-1.5 bar
- 1.5-2.0 bar
- 2.0-3.0 bar
- > 3.0 bar

New opened pipes



Current Status



Improved
system
resiliency

Perspective Scenario



enova
CONSULTANTS AND ENGINEERS
INSPIRED BY THE FUTURE



OPTIT
optimal solutions



Zemun-NB connection



DISTRICT ENERGY
IN CITIES
INITIATIVE



HYDRAULIC BENCHMARK

		Baseline	Simulated Scenario
Zemun	flow (kg/s)	246	0
Novi Beograd M1	flow (kg/s)	613	769
Novi Beograd M2	flow (kg/s)	643	800
Novi Beograd M3	flow (kg/s)	729	729
Novi Beograd M4	flow (kg/s)	638	638
Novi Beograd M5	flow (kg/s)	601	601
p supply (bar)		9.89	10.09
Novi Beograd M1-5 p return (bar)		1.90	2.05
Δp (bar)		7.99	8.04

CONCLUSIONS

The hydraulic balance complies with the technical constraints provided and adheres to the current conditions

The load in Zemun is taken on by the expanded capacity in NB, allowing the current local boiler house to be dismissed

The interconnection investment itself (without the costs of integrating TENT A) has an immediate payback time (< 2 months)

YEAR	NB-ZE CONNECTION											CUMULATED ACTUALIZED VALUE (RSD)
	NEW USERS SUPPLY (MWh)	NEW USERS REVENUE (RSD)	NEW USERS PRODUCTION COSTS (RSD)	PRODUCTION COSTS SAVINGS (RSD)	INVESTMENT COSTS (RSD)	AMORTIZATION (RSD)	GROSS FLUX (RSD)	TAXATION (RSD)	NET FLUX (RSD)	ACTUALIZATION COEFFICIENT (%)	ACTUALIZED VALUE (RSD)	
0	11 000	137 177 400	-64 705 882	931 764 706	-126 908 705	-4 230 290	1 000 005 933	-150 000 890	727 326 629	100.0%	727 326 629	727 326 629
1	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	98.0%	837 485 621	1 564 812 250
2	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	96.1%	821 064 334	2 385 876 584
3	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	94.2%	804 965 034	3 190 841 618
4	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	92.4%	789 181 406	3 980 023 024
5	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	90.6%	773 707 260	4 753 730 284
6	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	88.8%	758 536 530	5 512 266 814
7	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	87.1%	743 663 265	6 255 930 078
8	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	85.3%	729 081 632	6 985 011 710
9	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	83.7%	714 785 914	7 699 797 624
10	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	82.0%	700 770 504	8 400 568 128
11	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	80.4%	687 029 905	9 087 598 033
12	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	78.8%	673 558 731	9 761 156 764
13	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	77.3%	660 351 697	10 421 508 461
14	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	75.8%	647 403 624	11 068 912 085
15	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	74.3%	634 709 436	11 703 621 521
16	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	72.8%	622 264 153	12 325 885 673
17	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	71.4%	610 062 895	12 935 948 568
18	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	70.0%	598 100 877	13 534 049 445
19	11 000	137 177 400	-64 705 882	931 764 706	0	-4 230 290	1 000 005 933	-150 000 890	854 235 334	68.6%	586 373 409	14 120 422 854



ENOVA
CONSULTANTS AND ENGINEERS
INSPIRED BY THE FUTURE



Институт за геодестријску и картографску зивотност
Универзитет у Београду - Рударско-геолошки факултет



OPTIT
optimal solutions



New NB-DU-KO system



DISTRICT ENERGY
IN CITIES
INITIATIVE



INITIAL WORK CONDITIONS

- The multi-network connection will **maximize the supply of new sources** (especially at lower loads)
- Significant **altitude differences** pose technical challenges to pressure management
- Presence of **closed pipes** linking the separated networks may be an opportunity


Potential new
backbones
(green lines)

Potential
refurbishment of
existing backbones
(purple lines)

Planned new
pumping station(s)

Connection of
new users
(63 MW_{th})

Existing Boiler
stations (15
MW_{th}) to be
shut down



enova
CONSULTANTS AND ENGINEERS
INSPIRED BY THE FUTURE



OPTIT
optimal solutions



New NB-DU-KO system



DISTRICT ENERGY
IN CITIES
INITIATIVE



INVESTIGATION LINES

Hydraulic balance of the new aggregated network



Minimize operating pressures

Planned new piping vs refurbishment of existing assets



Trade-off between costs/technical Benefit

How to operate in low-load conditions



Is it feasible to rely on new sources only?

Impact of opening closed-down pipes



Does it improve the hydraulic balance?

Design of the new pumping station(s)



What is the required minimum Δp ?



New NB-DU-KO system




DISTRICT ENERGY
IN CITIES
INITIATIVE



SUMMARY OF RESULTS WORK CONDITIONS

The “outer ring”
has been proved
not to provide
significant benefit

Planning
guidelines have
been confirmed
and refined,
integrating
additional spot
actions



NB-DU-KO connection



DISTRICT ENERGY
IN CITIES
INITIATIVE




NEW NETWORK CONFIGURATION (100% FLOW)

Δp distribution

- 1.0-1.5 bar
- 1.5-2.0 bar
- 2.0-3.0 bar
- > 3.0 bar


Current Status



CURRENT STATUS


Shift in critical areas

Scenario 100% Flow (1)



SCENARIO 1: NB-DU-KO CONNECTION (100% FLOW)

Scenario 100% Flow (2)



Shift in critical areas

SCENARIO 2: NB-DU CONNECTION (100% FLOW)



enova
CONSULTANTS AND ENGINEERS
INSPIRED BY THE FUTURE





OPTIT
optimal solutions




HYDRAULIC REGIMES AT LOW LOADS

Δp distribution



In low load scenarios the heat coming from TENT-A serves an even larger portion of Dunav's system, allowing a decrease in Δp at the plant, without reaching critical conditions at the peripheral sections of the network



NB-DU-KO connection



DISTRICT ENERGY
IN CITIES
INITIATIVE



HYDRAULIC BENCHMARK

	Baseline	s 100% Flow (1)	s 100% Flow (2)	s 50% Flow
Dunav	p supply (bar)	12.00	12.00	12.00
	p return (bar)	7.12	7.12	6.30
	deltaP (bar)	4.88	4.88	2.52
Konjarnik	p supply (bar)	9.17	8.80	8.80
	p return (bar)	3.45	3.61	3.61
	deltaP (bar)	5.72	5.19	5.19
Novi Beograd M6	p supply (bar)	11.31	12.00	12.01
	p return (bar)	5.00	3.99	4.39
	deltaP (bar)	6.31	8.01	7.62

YEAR	NB-DU-KO CONNECTION										CUMULATED ACTUALIZED VALUE (RSD)
	NEW USERS SUPPLY (MWh)	NEW USERS REVENUE (RSD)	NEW USERS PRODUCTION COSTS (RSD)	PRODUCTION COSTS SAVINGS (RSD)	INFRASTRUCTURAL INVESTMENT COSTS (RSD)	AMORTIZATION (RSD)	NET FLUX (RSD)	TAXATION (RSD)	NET FLUX (RSD)	ACTUALIZATION COEFFICIENT (%)	
0	33 185	413 836 780	-88 729 412	971 105 882	-2 954 497 328	-98 483 244	1 197 730 007	-179 659 501	-1 837 943 578	100.0%	-1 837 943 578
1	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	98.0%	1 094 660 539
2	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	96.1%	1 073 196 607
3	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	94.2%	1 052 153 536
4	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	92.4%	1 031 523 075
5	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	90.6%	1 011 297 132
6	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	88.8%	991 467 777
7	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	87.1%	972 027 232
8	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	85.3%	952 967 874
9	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	83.7%	934 282 230
10	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	82.0%	915 962 970
11	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	80.4%	898 002 912
12	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	78.8%	880 395 012
13	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	77.3%	863 132 365
14	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	75.8%	846 208 201
15	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	74.3%	829 615 883
16	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	73.9%	813 348 905
17	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	71.4%	797 400 887
18	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	70.0%	781 765 576
19	33 185	413 836 780	-88 729 412	971 105 882	0	-98 483 244	1 197 730 007	-179 659 501	1 116 553 750	68.6%	766 436 839
	INDEX	VALUE									15 667 901 974
	NPV (RSD)	€ 15 667 901 974									



DISTRICT ENERGY
IN CITIES
INITIATIVE

CONCLUSIONS

The interconnection plan is feasible and may be achieved in different manners (S1 & S2), allowing for operational flexibility in case of boundary conditions variations (

Refurbishment of long segments of existing pipeline is necessary in order to comply with the technical constraints and avoid bottlenecks (yet, the outer ring has been seen to be superfluous)

In low-load conditions the new sources may be saturated within the technical constraints and many areas in Dunav and Konjarnik may be then served by TENT-A, decreasing the Δp required at the former plants.

The interconnection investment itself (without the costs of integrating TENT A) has an payback time of less than 3 years



Conclusions



DISTRICT ENERGY
IN CITIES
INITIATIVE



-  **The current networks have been configured into Optit's tool, with a successful validation against both SCADA data and TERMIS simulations**
-  **Lots of (+100) potential investment scenarios have been considered and analyzed, determining the best trade-off between investment costs and technical benefits**
-  **Interconnection scenarios are feasible and show increased operating flexibility in different load conditions, that can be exploited in light of future further network expansion**
-  **The finalized scenarios have been provided through cartographic data, KPI assessment and investment cash flow analysis**





Improving existing DH networks in Europe:

- Initiate the DH **upgrading process** for 8 systems up to the investment stage (Generation, Distribution, Use)
- Produce **Best Practices and Tools** Handbooks
- Develop regional / national action plans for DHN **retrofitting**
- **Replicate** the proposed solutions across Europe



This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 785014. The sole responsibility for the content of this report lies with the authors. It does not necessarily reflect the opinion of the European Union nor of the Executive Agency for Small and Medium-sized Enterprises (EASME). Neither the EASME nor the European Commission are responsible for any use that may be made of the information contained therein.



DISTRICT ENERGY
IN CITIES
INITIATIVE



Thank you for your attention!



OPTIT
optimal solutions

